

## UCH30 - 8193

PYROPLEX



### Application

Glazed apertures in fire resisting doors

### Fixing

Held by glass

### Performance

Fire tested to BS 476-20:22, BS EN 1634-1 & BS EN 1363-1

Certifire CF348

BM Trada Assessment 'Chilt/A08251'

### Material

Graphite based intumescent

### Glass thickness (mm)

5-7

### Length

100m coil

### Colour


Black

### Order codes

**UCH30/100** (15.5x10.7mm)

Cut lengths available

### Dimensions



 5 Regents Drive  
Prudhoe  
Northumberland  
NE42 6PX



[norseal.co.uk](http://norseal.co.uk)



[sales@norseal.co.uk](mailto:sales@norseal.co.uk)



01661 830088

Registered in Companies House Cardiff No. 04317595 VAT Reg. No. 733 9466 08