

FIRE STOPPING

BY NORSEAL

NON-VENTILATED FIRE BARRIER

TENMAT



Application

Vertical rainscreen/cladding cavities

Fixing

Screw fix with brackets

Performance

Fire tested to BS 476-20

Material

Mineral wool

Length (mm)

1000

Size (mm)

100xThickness (Cavity plus 10mm)

Order code

NVFB



 5 Regents Drive
Prudhoe
Northumberland
NE42 6PX

 norseal.co.uk

 firestopping@norseal.co.uk

 01661 520 930

Registered at Companies House Cardiff No. 04317595 VAT Reg. No. 733 9466 08

FIRE STOPPING

BY NORSEAL

Test Data

Fire Test Lab	Report Number	Construction	Fire Rating
BRE	243-505	Timber Frame	30
Exova Warringtonfire	A06037	Timber Frame	30-60
Exova Warringtonfire	A10030	Various	30-120
Exova Warringtonfire	A12315	Various	30-60
Exova Warringtonfire	IF06005	Timber Frame	30
Exova Warringtonfire	IF06013	Timber Frame	30-60
Exova Warringtonfire	IF06040	Concrete/Blockwork	120
Exova Warringtonfire	IF07077	Timber Frame	30
Exova Warringtonfire	IF08038	Block	90-120
Exova Warringtonfire	IF08052	Mineral Fibre/Timber Frame	30
Exova Warringtonfire	IF09011	Cement Board/Concrete	90
Exova Warringtonfire	IF09032	Concrete/Blockwork	30-90
Exova Warringtonfire	IF09093	Concrete/Blockwork	30-60
Exova Warringtonfire	IF10048	Concrete/Blockwork	120
Exova Warringtonfire	IF10060	Rigid Insulation & Blockwork	120
Exova Warringtonfire	IF11012	Concrete/Blockwork	120
Exova Warringtonfire	IF12016	Block	30-60



 5 Regents Drive
Prudhoe
Northumberland
NE42 6PX

 norseal.co.uk

 firestopping@norseal.co.uk

 01661 520 930

Registered at Companies House Cardiff No. 04317595 VAT Reg. No. 733 9466 08