

FIRE STOPPING

BY NORSEAL

DOWNLIGHTER COVER

TENMAT



Application

Cover downlight fixtures in ceiling penetrations

Fixing

Positioned in aperture

Performance

Fire tested to EN 1365-2, 13501-2 & BS 476

Acoustically tested to EN ISO 140/717

Material

Fire resistant mineral fibre

Sizes (mm)

150 x 150

(for downlighters with a cut-out size of 50-75mm)

200 x 200

(for downlighters with a cut-out size of 75-100mm)

250 x 250

(for downlighters with a cut-out size of 100-140mm)

Order codes

DC/ + Size

eg. DC/200x200 (200mm x 200mm)

 5 Regents Drive
Prudhoe
Northumberland
NE42 6PX

 norseal.co.uk

 firestopping@norseal.co.uk

 01661 520 930

Registered at Companies House Cardiff No. 04317595 VAT Reg. No. 733 9466 08

FIRE STOPPING

BY NORSEAL

Test Data

Report Type	Fire Test Lab	Report Number	Test Standard	Fire Rating
Classification	Giordano	311120/3599FR	EN 13501-2	120 mins
Fire Test	Giordano	311120/3599FR	EN 1365-2	120 mins
Fire Test	BRE	TE94667	EN 1365-2	60 mins
Assessment	Exova Warringtonfire	A02105	BS 476	60 mins
Fire Test	BRE	FG8962/208217	BS 476	60 mins
Fire Test	BRE	FG8962/208217	BS 476	60 mins
Fire Test	Exova Warringtonfire	IF99029	BS 476	60 mins
Fire Test	Exova Warringtonfire	IF03028	BS 476	120 mins
Assessment (Aus/NZ)	BRANZ	FAR2032	AS1530.4	60 mins
Application Report	BRANZ	FC2032	AS1530.4	60 mins
Acoustic Test	BRE	213942	EN ISO 140/717	Pass



 5 Regents Drive
Prudhoe
Northumberland
NE42 6PX

 norseal.co.uk

 firestopping@norseal.co.uk

 01661 520 930

Registered at Companies House Cardiff No. 04317595 VAT Reg. No. 733 9466 08