

FIRE STOPPING

BY NORSEAL

FIRE RATED AIR VALVES

TENMAT



Application

Fire-rated ceilings requiring recessed ceiling air valves

Fixing

Screw fix

Performance

Meets requirements of Approved Document B

Material

Intumescent material

Sizes (mm)

80, 100, 125, 150, 200

EXTRACT VALVE

Order code

EV + Size eg. *EV80 (80mm diameter)*

SUPPLY VALVE

Order code

SV + Size eg. *SV80 (80mm diameter)*

Test Data

Report Type	Fire Test Lab	Report Number	Construction	Fire Rating
Fire Test	The Building Test Centre	BTC 18074F	Timber Joist/GTEC Fire Board Floor	60
Fire Test	Chiltern Fire	IF10090	Plasterboard	60

 5 Regents Drive
Prudhoe
Northumberland
NE42 6PX

 norseal.co.uk

 firestopping@norseal.co.uk

 01661 520 930

Registered at Companies House Cardiff No. 04317595 VAT Reg. No. 733 9466 08