

# FIRE STOPPING

BY NORSEAL

## LOFT COVER

TENMAT



### Application

Cover downlight fixtures in ceiling penetrations

### Fixing

Positioned over light fitting to allow safe installation of loft insulation.

### Performance

Tested to EN/IEC 60598  
Certified IP6 Dust Tight

### Material

Fire resistant mineral fibre

### Order code

#### LC/ + Type

eg. LC/FF120 (150mm x 225mm x 275mm)

### Sizes (mm)

Type	Nominal Internal Height	Nominal Diameter (top)	Nominal Diameter (base)
FF120	150	225	275
FF130	150	85	240 - 250

 5 Regents Drive  
Prudhoe  
Northumberland  
NE42 6PX



norseal.co.uk



firestopping@norseal.co.uk



01661 520 930

Registered at Companies House Cardiff No. 04317595 VAT Reg. No. 733 9466 08

# FIRE STOPPING

BY NORSEAL

## Test Data

Report Type	Fire Test Lab	Report Number	Test Standard	Fire Rating
Reaction to Fire (FF120)	BRE	302306-2	EN 13501-1	A1
Flammability Test	LIA	L12459A	EN 60695	Pass
Heat Build Up Tests	LIA	L9807C, L10539B (Amd1), L9807B, L10539 (Amd2)	EN 60598	Pass
Heat Build Up Tests and Flammability	LIA	L11911 Amd2	UL1598 & IEC60598	Pass
IP6X Resistance Test	LIA	L12459	EN 60598	Pass
Reaction to Fire	BRE	302306-1	EN ISO 1182:2010	-
Air Tightness	Exova	P09020/01	EN 1026:2000	-
Air Tightness	Exova	P11032	EN 1026:2000	-
Lumen Output	LIA	L13178	EN 60598	-
Energy Efficiency	Exova	TT/F09323-1	-	-



 5 Regents Drive  
Prudhoe  
Northumberland  
NE42 6PX

 [norseal.co.uk](http://norseal.co.uk)

 [firestopping@norseal.co.uk](mailto:firestopping@norseal.co.uk)

 01661 520 930

Registered at Companies House Cardiff No. 04317595 VAT Reg. No. 733 9466 08